

University of South Australia

Confined Space Audit Assessment Register of Authorised Access Only

Consultant: Roger Palubinski
Safety & Risk Consultant
Sustainable Risk Solutions

Client contact: Ms Leanne Haller
Business & Administration Co-ordinator

Date of service: August 2006

Acknowledgments

The auditor would like to take this opportunity to thank the management and employees of the University of South Australia for their co-operation, sincerity and tolerance during the occupational health and safety management systems audit.

In particular, Mr Barry Mather (Electrical Services Officer) for his assistance and accompaniment during the audit process. His knowledge and understanding of the campuses was extremely helpful.

Note: Any information or advice given in the provision of this service to members, or non members, is on the basis of the client's needs, having regard to the nature and scope of such service. Accordingly, no responsibility of liability is accepted to legal proceedings for failure of any statutory or other duty under any Act or award, whether or not such proceedings arise directly or indirectly from any advice given by the **Sustainable Risk Solutions** or its officers.

Contents

| | | |
|-----|---|----|
| 1. | Magill campus – confined space assessments | 4 |
| 2. | City East campus – confined space assessments | 11 |
| 3. | City West campus – confined space assessments | 29 |
| 4. | Flexible Learning Centre – confined space assessments | 57 |
| 5. | Whyalla campus – confined space assessments | 60 |
| 6. | Mawson Lakes campus – confined space assessments | 64 |
| 7. | Magill campus Action Plan | 92 |
| 8. | City East campus Action Plan | 92 |
| 9. | City West campus Action Plan | 93 |
| 10. | Flexible Learning Centre Action Plan | 93 |
| 11. | Whyalla campus Action Plan | 94 |
| 12. | Mawson Lakes campus Action Plan | 94 |

The University of South Australia Magill Campus

Confined Space Assessment
28 August 2006

Register of Authorised Access Only

| Magill Campus University of South Australia | | JUSTIFICATION | | | | | | | |
|--|--|--------------------------------|---------------------------------------|---------------------------------|------------------------------------|--------------------------------|----------------------|--------------------------|-----------------------------|
| Confined Space Audit Date: 29 August 2006 | | AND | | | OR | | | AND | |
| Building and Location | Descriptor | Enclosed or partially enclosed | Atmospheric pressure during occupancy | Not intended as a place of work | Potential atmospheric contaminants | Potential deficiency or excess | May cause engulfment | Restricted entry or exit | Confined space Yes or No |
| Building A Level 1 | A1 – 01 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building A Level 1 | A1 – 14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building A Level 1 | KAF Area Ceiling Access Panels in Servery | No | Yes | No | No | No | No | No | No |
| Building A Level 1 | A1 – 15 Dumb Waiter | No | Yes | No | No | No | No | No | No |
| Building A Level 2 | A2 – 21C Cleaners Room | No | Yes | No | No | No | No | No | No |
| Building A Level 2 | A2 – 23A Storeroom to roof access ladder | No | Yes | No | No | No | No | No | No |
| Building B Level 1 | B1 – 32 Switch Room | No | Yes | No | No | No | No | No | No |
| Building B Level 1 | B1 – 40 Switch Room | No | Yes | No | No | No | No | No | No |
| Building B Level 1 | B1 – 42 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|--|----|-----|----|----|----|----|----|----|
| Building B Level 1 | B1-80 Switch Board | No | Yes | No | No | No | No | No | No |
| Building B Level 1 | B1-41 Transformer Room | No | Yes | No | No | No | No | No | No |
| Building B Level 2 | B 2 – 25A General Plant Room B2 25B Switch board | No | Yes | No | No | No | No | No | No |
| Building B Level 2 | B2 – 26 Library, Lift Plant Room | No | Yes | No | No | No | No | No | No |
| Building B Level 2 | D 5 -14 Roof Access Doors | No | Yes | No | No | No | No | No | No |
| Building B Level 2 | B2 – 37 Roof Access | No | Yes | No | No | No | No | No | No |
| Building B Level 2 | B2 – 44 & B2 – 45 Plant Rooms | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1- 01 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1- 23 Switch board | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1- 69 Switch Room | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1 – 80 Plant Room | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C2 – 29 Switch Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|--|-----|-----|----|----|----|----|-----|----|
| Building C Level 2 | C2 – 34 Plant Room | No | Yes | No | No | No | No | No | No |
| Building C Level 2 | C1- 47 Switch Room | No | Yes | No | No | No | No | No | No |
| Building D Level 1 | D1 – 08 Storeroom | No | Yes | No | No | No | No | No | No |
| Building D Level 1 | D1 – 12 & D1 – 14 Ladder Access Rooms | No | Yes | No | No | No | No | No | No |
| Building D Level 1 | D1 – 21 & D1 – 22 Store Room and Electrical Distribution Board | No | Yes | No | No | No | No | No | No |
| Building D Level 1 | D1 – 18 Plant Room | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1-15 (Gymnasium) Hot Water Services Plant Room | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1 – 13 Electrical Switch Room | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1 – 01 Store/Comms | No | Yes | No | No | No | No | No | No |
| Building F | F1-01 Store Room | No | Yes | No | No | No | No | No | No |
| Building F | F1-02 Plant & Pump Room | No | Yes | No | No | No | No | No | No |
| Building G Level 1 | Access to A/C Plant Room Court Yard 2 | Yes | Yes | No | No | No | No | Yes | No |

| | | | | | | | | | |
|-----------------------|---|-----|-----|----|----|----|----|-----|----|
| Building G Level 1 | G1 – 66 Electrical Switchboard | No | Yes | No | No | No | No | No | No |
| Building G Level 1 | G1 – 67 FHR | No | Yes | No | No | No | No | No | No |
| Building G Level 1 | G1 – 74 Plant Room in Observation Mezzanine | No | Yes | No | No | No | No | No | No |
| Building G Level 1 | G1 88 Electrical Switch and Comms Room | No | Yes | No | No | No | No | No | No |
| Building G Level 1 | G1-87 Plant Room | No | Yes | No | No | No | No | No | No |
| Building G Level 1 | G1 - 09 and G1 – 10 Fire Service & Hot Water Service | No | Yes | No | No | No | No | No | No |
| Building G Level 1 | G1 - 46 A/C Plant Room | Yes | Yes | No | No | No | No | Yes | No |
| Building G Level 1 | G1 - 47 Duct | Yes | Yes | No | No | No | No | Yes | No |
| Building H Level 1 | H1 -52 FHR | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1 - 47 Electrical Switchboard | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1 - 51 Electrical Switchboard | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2 – 31A Electrical Switchboard | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|--|-----|-----|----|----|----|----|----|----|
| Building H Level 2 | H2 – 31B Electrical Switchboard | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2 – 14 and H2 – 15 Electrical Comm. And Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2 – 06A and H2 – 06B Electrical Comms and Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2 – 14 Electrical Comms Room | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2 – 15 Lift Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2 – 16 Cleaners Room | No | Yes | No | No | No | No | No | No |
| Building K Level 1 | K1 - 01 and K1 – 25 Electrical Switchboard and Extinguisher cupboard | No | Yes | No | No | No | No | No | No |
| General Site Works | Concrete Slab Control Station Raised Bore Pump Control Station | Yes | Yes | No | No | No | No | No | No |
| General Site Works | Storm Water Pit Northern side of Building D | Yes | Yes | No | No | No | No | No | No |
| General Site Works | Storm Water Pit Northern side of Building D | Yes | Yes | No | No | No | No | No | No |
| General Site Works | Storm Water Pit Lawn, Eastern Side Building E | Yes | Yes | No | No | No | No | No | No |
| General Site Works | Storm Water Pit Lawn, Eastern Side Building E | Yes | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------|---|-----|-----|----|----|----|----|-----|----|
| General Site Works | Round Concrete Gatic Covered Valve Control Station & Pit , Near 3 rd Cross Over Bridge | Yes | Yes | No | No | No | No | Yes | No |
|--------------------|---|-----|-----|----|----|----|----|-----|----|

The University of South Australia City East

Confined Space Assessment
11 September 2006

Register of Authorised Access Only

| City East Campus University of South Australia | | JUSTIFICATION | | | | | | | |
|---|--|--------------------------------|---------------------------------------|---------------------------------|------------------------------------|--------------------------------|----------------------|--------------------------|-----------------------------|
| Confined Space Audit Date: 11 September 2006 | | AND | | | OR | | | AND | |
| Building and Location | Descriptor | Enclosed or partially enclosed | Atmospheric Pressure During occupancy | Not intended as a place of work | Potential atmospheric contaminants | Potential deficiency or excess | May cause engulfment | Restricted entry or exit | Confined space Yes or No |
| Brookman Building Level 3 | D1-10 and D1- 11 Access pit (Ext) Airconditioning Plant Western Side | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 3 | D1- 12 and D1-15 Light Tunnel under central staircase main entrance steps (Ext), Southernside | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 3 | D1- 17 and D1-22 Gardner's shed (ext) | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 3 | BB3-26 & BB3 – 26A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 3 | BB3-26 Switchboard | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 3 | BB3-26A Switchboard | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 4 | B4- 07D Store Room | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 4 | B4-09 Telecom | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-------------------------------|---|----|-----|----|----|----|----|----|----|
| Brookman Building Level 4 | BB M-04 Lift Plant Room | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 5 | B5-07 Electrical/Communication Data Riser | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 5 | B5-01A General Plant Room | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 6 | B6-15A Female Access Toilets Access Panel in Ceiling | No | Yes | No | No | No | No | No | No |
| Brookman Building Level 6 | B6-02 Cleaners Room & Ceiling Access | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 2 | C2 – 17 C2-17A, C2-17B and C2-17C Electrical Plant, Switch Room and Chillers | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 2 | D6 21 22 24 Sub Station Area | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 2 | C2-14D Service Void | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 2 | C2-05 Switchboard | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 2 | C2-06 Communications Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 2 | C2-17 General A/C Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 2 | C2 -17C Plant and Boiler Rooms | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-------------------------------|---|----|-----|----|----|----|----|----|----|
| Centenary Building Level 3 | C3-12 General Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 3 | C3-28 Service Void | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 3 | C3-16A Service Void | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 3 | C3-04 Service Void | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 3 | C3-05 Telecommunications | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 3 | C3-06 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 3 | C3-18 Communications Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 4 | C4 -15 General Electrical & Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 4 | C4-47 General Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 4 | C4-26 Mechanical Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 4 | C4-03 Telecommunications Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 4 | C4-05 Data Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-------------------------------|--|----|-----|----|----|----|----|----|----|
| Centenary Building Level 4 | C4-06 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 5 | C5-20 General Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 5 | C5-27 Mechanical Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 5 | C5-03 Telecommunications | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 5 | C5-05 Data Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 5 | C5-06 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 5 | C5-10 General Electrical & Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 5 | C5-50 General Electrical & Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 6 | C6-23 General Electrical & Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 6 | C6-12 General Electrical & Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 6 | C6-58 General Electrical & Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 6 | C6-34 Mechanical Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-------------------------------|-------------------------------|----|-----|----|----|----|----|----|----|
| Centenary Building Level 6 | C6-03 Telecommunications | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 6 | C6-05 Data Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 6 | C6-06 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-03 Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-38 Duct | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-09A General Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-17 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-19 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-18 Communications Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-29 Communications Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-28 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-59 Distribution Board | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-------------------------------|-------------------------------|----|-----|----|----|----|----|----|----|
| Centenary Building Level 7 | C7-60 Communications Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-07 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 7 | C7-06 Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-38A Mechanical Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-25 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-24 Communications Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-50 Communications Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-52 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-07 Service Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-05 Service Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-03 Service Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-04 Distribution Board | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-------------------------------|-------------------------------|----|-----|----|----|----|----|-----|----|
| Centenary Building Level 8 | C8-14 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-16 Distribution Board | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-15 Communications Riser | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 8 | C8-08 General Plant Room | No | Yes | No | No | No | No | Yes | No |
| Centenary Building Level 8 | C8-09 General Plant Room | No | Yes | No | No | No | No | Yes | No |
| Centenary Building Level 9 | C9-01 General Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 9 | C9-02 Lift Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 9 | C9-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 9 | C9-01 Thru to Roof Access | No | Yes | No | No | No | No | No | No |
| Centenary Building Level 9 | C9-02 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 1 | P1-07 Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 1 | P1-11 Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------------|--|----|-----|----|----|----|----|-----|----|
| Playford Building Level 1 | P1-36 Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 1 | P1-01A Communication Riser | No | Yes | No | No | No | No | No | No |
| Playford Building Level 1 | P1-01B Switch Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 2 | P2-50 General Plant & Electrical Switch Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 2 | P2-04 Service Duct | No | Yes | No | No | No | No | Yes | No |
| Playford Building Level 2 | P 2-07B & P 2-07C Store Room and Ceiling Access | No | Yes | No | No | No | No | No | No |
| Playford Building Level 2 | P2-55B and P2-55C General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 2 | P2-20 Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 2 | P2-19 Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 2 | P2-30 Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 3 | P3-09A Service Duct | No | Yes | No | No | No | No | No | No |
| Playford Building Level 3 | P3-49A Switch Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------------|---|----|-----|----|----|----|----|----|----|
| Playford Building Level 3 | P3-38B Electrical/Communication Data Riser | No | Yes | No | No | No | No | No | No |
| Playford Building Level 3 | P3-23 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 3 | P3-18A General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 3 | P3-31 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 4 | P4-56 Service Duct | No | Yes | No | No | No | No | No | No |
| Playford Building Level 4 | P4-14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 4 | P4-19 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 4 | P4-54 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Playford Building Level 4 | P4-35 Communications Riser | No | Yes | No | No | No | No | No | No |
| Playford Building Level 5 | P5-06 Service Duct | No | Yes | No | No | No | No | No | No |
| Playford Building Level 5 | P5-09 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 5 | P5-01 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Playford Building Level 5 | P5-61 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 5 | P5-24 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 5 | P5-59 Service Duct | No | Yes | No | No | No | No | No | No |
| Playford Building Level 5 | P5-43 & P5-44 Service Duct | No | Yes | No | No | No | No | No | No |
| Playford Building Level 6 | P6 -57 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 6 | P6 -22 Service Duct | No | Yes | No | No | No | No | No | No |
| Playford Building Level 6 | P6-37A Electrical Switch Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 6 | P6-59 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 6 | P6-19 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 7 | P7-48 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 7 | P7-47 Electrical Switch Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 7 | P7- 03 Service Duct | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------------------|---|----|-----|----|----|----|----|----|----|
| Playford Building Level 7 | P7- 49 & P7-49A General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 8 | P8-02 General Plant Room | No | Yes | No | No | No | No | No | No |
| Playford Building Level 8 | P8-05 & P8-05A Lift Rooms | No | Yes | No | No | No | No | No | No |
| Playford Building Level 8 | P8-04 General Plant Rooms | No | Yes | No | No | No | No | No | No |
| Playford Building Level 8 | P8-08 and P8-09 Roof General Plan t& Lift Room | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 1 | BJ1-14 Electrical Switch Board | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 1 | BJ1-47 General Plant Room | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 1 | BJ1-57 Switch Room | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 1 | BJ1-04B Duct | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 1 | BJ1-33A General Plant Room | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 2 | BJ2-44 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------------------|--|----|-----|----|----|----|----|----|----|
| Bonython Jubilee Building Level 2 | BJ 2 -63 and BJ-65 Ceiling access in Men's Toilet | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 2 | BJ2-30A Electrical Distribution Board | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 2 | BJ2-01B Electrical Distribution Board | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 2 | BJ2-30B General Plant Room | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 2 | BJ2-33 Communications Riser | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 3 | BJ 3 65 Ceiling access in Men's Toilet | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 3 | BJ3-58 General Plant Room | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 3 | BJ3-01A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 3 | BJ3-04 Cleaners Room Service void | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 3 | BJ3-33 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------------------|--|----|-----|----|----|----|----|----|----|
| Bonython Jubilee Building Level 3 | BJ3-35 Electrical Distribution Board | No | Yes | No | No | No | No | No | No |
| Bonython Jubilee Building Level 3 | BJ3-64 Electrical Distribution Board | No | Yes | No | No | No | No | No | No |
| Reid Building Basement Level | R0 - 02A General Plant Room | No | Yes | No | No | No | No | No | No |
| Reid Building Basement Level | R0 – 12, R0 - 12A and RO - 12B Electrical Switch and Communications Rooms | No | Yes | No | No | No | No | No | No |
| Reid Building Basement Level | R0 – 15B General Plant | No | Yes | No | No | No | No | No | No |
| Reid Building Level 1 | R1-08A Switchboard 4 | No | Yes | No | No | No | No | No | No |
| Reid Building Level 1 | R1-08A Communications 3 | No | Yes | No | No | No | No | No | No |
| Reid Building Level 1 | R1-05A Communications 4 | No | Yes | No | No | No | No | No | No |
| Reid Building Level 1 | R1- 05 Switch Board | No | Yes | No | No | No | No | No | No |
| Reid Building Level 2 | R2 - 20 Plant Room | No | Yes | No | No | No | No | No | No |
| Reid Building Level 2 | R2 - 29 Communications | No | Yes | No | No | No | No | No | No |
| Reid Building Level 3 | R3 – 30 Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------|--|----|-----|----|----|----|----|----|----|
| Reid Building Level 3 | R3 – 44 Services | No | Yes | No | No | No | No | No | No |
| Reid Building Level 3 | R3 – 43 Services | No | Yes | No | No | No | No | No | No |
| Reid Building Level 3 | R3 – 42 Services | No | Yes | No | No | No | No | No | No |
| Reid Building Level 3 | R3 – 41 Services | No | Yes | No | No | No | No | No | No |
| Reid Building Level 3 | R3 – 40 Services | No | Yes | No | No | No | No | No | No |
| Reid Building Level 4 | R4 – 27 Plant Room | No | Yes | No | No | No | No | No | No |
| Reid Building Level 4 | R4 – 07 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 4 | R4 – 09 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 4 | R4 – 10 and R4-10A Electrical Switchboard | No | Yes | No | No | No | No | No | No |
| Reid Building Level 4 | R4 – 16 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 4 | R4 – 10B Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 4 | R4 – 14 Electrical Switchboard | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------|---|----|-----|----|----|----|----|----|----|
| Reid Building Level 4 | R4 – 13A Serv Isol | No | Yes | No | No | No | No | No | No |
| Reid Building Level 4 | R4 – 18 Serv Isol | No | Yes | No | No | No | No | No | No |
| Reid Building Level 5 | R5 – 29 Plant Room | No | Yes | No | No | No | No | No | No |
| Reid Building Level 5 | R5 – 09 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 5 | R5 – 7 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 5 | R5 – 10, R5 – 10A and R5 – 10B Switchboards and Service Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 5 | R5 – 12 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 5 | R5 – 14 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 5 | R5 – 16 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 5 | R5 – 18 Isol | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-24 AC Plant Room | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-06 Duct | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------|------------------------------|----|-----|----|----|----|----|----|----|
| Reid Building Level 6 | R6-05 Server Isol | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-06 Comms | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-09 Switchboard | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-09C Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-11 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-11A Serv Isol | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-12 Switchboard | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-13 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-15 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 6 | R6-16 Duct | No | Yes | No | No | No | No | No | No |
| Reid Building Level 8 | R8-01 Lift Motor Room | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 2 | H2-27C Distribution Board | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------|--------------------------------|----|-----|----|----|----|----|----|----|
| Hetzel Building Level 2 | H2-27D Communications Riser | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 2 | H2-28 General Plant Room | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 3 | H3-27A Distribution Board | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 3 | H3-27D Communications Riser | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 4 | H4-28C Riser | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 4 | H4-28A Distribution Board | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 4 | H4-28D Communications Riser | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 5 | H5-27C Riser | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 5 | H5-27A Distribution Board | No | Yes | No | No | No | No | No | No |
| Hetzel Building Level 5 | H5-28A Communications Riser | No | Yes | No | No | No | No | No | No |

The University of South Australia City West

Confined Space Assessment
28 August 2006

Register of Authorised Access Only

| City West Campus University of South Australia | | JUSTIFICATION | | | | | | | |
|---|---|--------------------------------|---------------------------------------|---------------------------------|------------------------------------|--------------------------------|----------------------|--------------------------|-----------------------------|
| Confined Space Audit Date: 31 August 2006 | | AND | | | OR | | | AND | |
| Building and Location | Descriptor | Enclosed or partially enclosed | Atmospheric Pressure during occupancy | Not intended as a place of work | Potential atmospheric contaminants | Potential deficiency or excess | May cause engulfment | Restricted entry or exit | Confined space Yes or No |
| Yungondi Building Level 1 | Y1-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building External | Underfloor access General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1 12 Plant Room -13 Access toilet Ceiling Panels in Ceiling | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1-39 Communication Risers | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1-07 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1-76 Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1-72B Electrical & Communication Risers | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1-10 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------------|---|----|-----|----|----|----|----|----|----|
| Yungondi Building Level 1 | Y1-23B Electrical & Communication Risers | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1-23A Distribution Board | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1-14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 1 | Y1-12 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-11 Roof Access Doors | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-09 Male Toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-12 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-10 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-07 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-18B Communication Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------------|---|----|-----|----|----|----|----|----|----|
| Yungondi Building Level 2 | Y2-18C Electrical Board | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-22A Electrical Board | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-22B Communication Riser | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 2 | Y2-82 Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3 -18B Electrical & Communication Risers | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3 -18C Distribution Board | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-12 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-02 Male toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-09 Female toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-22 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------------|---|----|-----|----|----|----|----|----|----|
| Yungondi Building Level 3 | Y3-22A Distribution Board | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-22B Communications Riser | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-10 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 3 | Y3-07 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-26 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-67 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-65 Female Toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-62 Male Toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-80A Distribution Board | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-80B Communications Riser | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-55 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------------------|---|----|-----|----|----|----|----|----|----|
| Yungondi Building Level 4 | Y4-58 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-59 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-61 General Plant Room | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-83B Communications Riser | No | Yes | No | No | No | No | No | No |
| Yungondi Building Level 4 | Y4-83C Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 1 | BH 1-10 Male Toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 1 | BH 1-22 Female Toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 2 | BH 2-M1 General Plant Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 2 | BH 2-M2 General Plant Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 2 | BH 2-06B Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 2 | BH 2-06C Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------------------|-------------------------------------|----|-----|----|----|----|----|-----|----|
| Barbara Hanrahan Building Level 2 | BH2 17-18 Theatre Plant Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 2 | BH2 – 26A Electrical Switch Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 2 | BH2 – 06G Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 2 | BH2 – 06H Communications Riser | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 3 | BH3 – 05B Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 3 | BH 3 - 05C Communication Risers | No | Yes | No | No | No | No | Yes | No |
| Barbara Hanrahan Building Level 3 | BH 3 - 06H Communication Risers | No | Yes | No | No | No | No | Yes | No |
| Barbara Hanrahan Building Level 3 | BH3 – 06J Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 3 | BH 3 -15 General Plant Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 3 | BH 3 -08 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------------------|---|----|-----|----|----|----|----|-----|----|
| Barbara Hanrahan Building Level 3 | BH 3-07 Female Toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 3 | BH 3-37 Male Toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 3 | BH 3 - 06A Communication Risers | No | Yes | No | No | No | No | Yes | No |
| Barbara Hanrahan Building Level 3 | BH3 – 06B Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 4 | BH 4-05B Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 4 | BH 4-05C Communications Riser | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 4 | BH 4-34 & BH 4-37 General Plant Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 4 | BH 4-25B Communications Riser | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 4 | BH 4-25C Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 4 | BH 4-06A Electrical Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------------------|---|----|-----|----|----|----|----|----|----|
| Barbara Hanrahan Building Level 4 | BH 4-06B Communications Riser | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 4 | BH 4-07 General Plant Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH 5-05B Communications Riser | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH 5-05C Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH-20 Female Toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH-14D Communications Riser | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH-14E Distribution Board | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH 5-13 General Plant Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH 5-17 General Plant Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH-06B Distribution Board | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------------------|---|----|-----|----|----|----|----|----|----|
| Barbara Hanrahan Building Level 5 | BH-06C Communications Riser | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH 5-08 General Plant Room | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 5 | BH 5-21 Male Toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Barbara Hanrahan Building Level 6 | Roof Top Lift Plant Rooms | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 2 | HH 2 -04F Communications Riser | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 2 | HH 2 -01D Distribution Board | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 2 | HH 2 -20 Main Switchboard | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 3 | HH 3-01B Communication Riser | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 3 | HH 3-01F Distribution Board | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 3 | HH 3-10 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--|--|----|-----|----|----|----|----|----|----|
| Sir Hans Heysen Building Level 3 | HH 3-10A General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 3 | HH 3-10B General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 3 | HH 3-10C General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 4 | HH 4-09 General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 4 | HH 4-01B Communication Riser | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 4 | HH 4-01G Distribution Board | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 5 | HH 5-01B Communications Riser | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 5 | HH 5-01H Distribution Board | No | Yes | No | No | No | No | No | No |
| Sir Hans Heysen Building Level 5 | HH 5-06 Store room to access ladder | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 2 | CS 2-02C Service Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--|----------------------------------|----|-----|----|----|----|----|----|----|
| Catherine Helen Spence Building Level 2 | CS 2-02B Communications Riser | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 2 | CS 2-02A Distribution Board | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 2 | CS 2-23 General Plant Room | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 3 | CS 3-01C Service Riser | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 3 | CS 3-01B Communications Riser | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 3 | CS 3-01A Distribution Board | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 3 | CS 3-24 General Plant Room | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 3 | CS 3-26 General Plant Room | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 3 | CS 3-01F Communications Riser | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 3 | CS 3-01G Distribution Board | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--|----------------------------------|----|-----|----|----|----|----|----|----|
| Catherine Helen Spence Building Level 3 | CS 3-01E Security | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 4 | CS 4-23 General Plant Room | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 4 | CS 4-01C Service Riser | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 4 | CS 4-01B Communications Riser | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 4 | CS 4-01A Distribution Board | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 4 | CS 4-01E Distribution Board | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 4 | CS 4-01F Communications Riser | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 4 | CS 4-01G Distribution Board | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 4 | CS 4-24 General Plant Room | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 4 | CS 4-26 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--|--|----|-----|----|----|----|----|----|----|
| Catherine Helen Spence Building Level 5 | CS 5-23 General Plant Room | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 5 | CS 5-01C Service Riser | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 5 | CS 5-01B Communications Riser | No | Yes | No | No | No | No | No | No |
| Catherine Helen Spence Building Level 5 | CS 5-01A Distribution Board | No | Yes | No | No | No | No | No | No |
| Child Care Centre Hindley Street | Located G1- 37 Storeroom/Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 1 | EM 1-04 PABX Room & Under Floor Service Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 2 | EM 2-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 2 | EM 2-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 2 | EM2-11c & EM2-11b Electrical Switchboard & Communication Risers | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 2 | EM 2-02 Female toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 2 | EM 2-08 Male toilets Ceiling Service Duct Access | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Elton Mayo Building Level 3 | EM 3-09 General Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 3 | EM 3-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 3 | EM 3-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 3 | EM 3-11B Communications Riser | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 3 | EM 3-11C Distribution Board | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 4 | EM 4-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 4 | EM 4-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 4 | EM 4-11B Communications Riser | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 4 | EM 4-11C Distribution Board | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 5 | EM 5-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 5 | EM 5-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Elton Mayo Building Level 5 | EM 5-11B Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|---|--|----|-----|----|----|----|----|----|----|
| Elton Mayo Building Level 5 | EM 5-11C Distribution Board | No | Yes | No | No | No | No | No | No |
| Rowland Rees Building Level 2 | RR 2-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Rowland Rees Building Level 2 | RR 2-01A & B Electrical Switchboard & Communication Risers | No | Yes | No | No | No | No | No | No |
| Rowland Rees Building Level 3 | RR 3-07 A & B Electrical Switchboard & Communication Risers | No | Yes | No | No | No | No | No | No |
| Rowland Rees Building Level 3 | RR 3-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Rowland Rees Building Level 4 | RR 4 - 07 A & B Electrical Switchboard & Communication Risers | No | Yes | No | No | No | No | No | No |
| Rowland Rees Building Level 4 | RR 4-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Rowland Rees Building Level 5 | RR- 5 02A & RR 5-02B Electrical Switchboard & Communication Risers | No | Yes | No | No | No | No | No | No |
| Rowland Rees Building Level 5 | RR 5-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 2 | GK 2-28 General Plant | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|---|----------------------------------|----|-----|----|----|----|----|----|----|
| Sir George Kingston Building Level 2 | GK 2-03B Distribution Boards | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 2 | GK 2-04D Distribution Boards | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 2 | GK 2-04C Communication Risers | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 2 | GK 2-03C Communication Risers | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 2 | GK 2-08 General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 3 | GK 3-13 General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 3 | GK 3-03B Distribution Boards | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 3 | GK 3-03C Communication Risers | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 3 | GK 3-04C Distribution Boards | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 3 | GK 3-04B Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|---|----------------------------------|----|-----|----|----|----|----|----|----|
| Sir George Kingston Building Level 3 | GK 3 3-08 General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 3 | GK 3 3-13 General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 4 | GK 4-03B Communication Risers | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 4 | GK 4-03C Distribution Boards | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 4 | GK 4-04C Distribution Boards | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 4 | GK 4-04B Communications Riser | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 4 | GK 4 4-13 General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 4 | GK 4 4-08 General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 5 | GK 5 5-13 General Plant Room | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 5 | GK 5 5-08 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|---|------------------------------------|----|-----|----|----|----|----|----|----|
| Sir George Kingston Building Level 5 | GK 5-03B Distribution Board | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 5 | GK 5-03C Communications Riser | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 5 | GK 5-04C Distribution Boards | No | Yes | No | No | No | No | No | No |
| Sir George Kingston Building Level 5 | GK 5-04B Communications Riser | No | Yes | No | No | No | No | No | No |
| Way Lee Building | Under Floor Access Room (External) | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-08 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-20B Communications Riser | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-20C Distribution Board | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-21B Communications Riser | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-21C Distribution Board | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Way Lee Building Level 2 | WL 2-59 Communications Riser | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-16 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 2 | WL 2-11 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 3 | WL 3-11 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 3 | WL 3-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 3 | WL 3-16 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 3 | WL 3-14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 3 | WL 3-23B Communications Riser | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 3 | WL 3-23C Distribution Board | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 3 | WL 3-19B Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Way Lee Building Level 3 | WL 3-19C Distribution Board | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 3 | WL 3-08 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 3 | WL 3-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 4 | WL 4-11 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 4 | WL 4-13B Communications Riser | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 4 | WL 4-13C Distribution Board | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 4 | WL 4-05B Communications Riser | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 4 | WL 4-05C Distribution Board | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 4 | WL 4-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 4 | WL 4-16 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 4 | WL 4-14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 4 | WL 4-08 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Way Lee Building Level 4 | WL 4-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-11 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-16 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-08 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-06 General Plant Room | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-13B Communications Riser | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-13C Distribution Board | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-05B Communications Riser | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 5 | WL 5-05C Distribution Board | No | Yes | No | No | No | No | No | No |
| Way Lee Building Level 6 | General Plant Room on Roof | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------------|---------------------------------|----|-----|----|----|----|----|----|----|
| Dorrit Black Building Level 3 | DB 3-01A Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 3 | DB 3-13A Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 3 | DB 3-01E Distribution Boards | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 3 | DB 3-13C Distribution Boards | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 3 | DB 3-01D Security Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 3 | DB 3-13B Security Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 3 | DB 3-04 Main Switch Room | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 3 | DB 3-12 General Plant Room | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 4 | DB 4-01A Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 4 | DB 4-01B Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 4 | DB 4-01H Distribution Board | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 4 | DB 4-01E Distribution Board | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Dorrit Black Building Level 4 | DB 4-01D Security Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 4 | DB 4-01G Security Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 4 | DB 4-01C Communications Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 4 | DB 4-01F Communications Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 5 | DB 5-01A Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 5 | DB 5-01B Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 5 | DB 5-01H Distribution Board | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 5 | DB 5-01E Distribution Board | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 5 | DB 5-01D Security Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 5 | DB 5-01G Security Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 5 | DB 5-01C Communications Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 5 | DB 5-01F Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Dorrit Black Building Level 6 | DB 6-01A Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 6 | DB 6-01B Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 6 | DB 6-01H Distribution Board | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 6 | DB 6-01E Distribution Board | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 6 | DB 6-01D Security Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 6 | DB 6-01G Security Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 6 | DB 6-01C Communications Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 6 | DB 6-01F Communications Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 7 | DB 7-01A Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 7 | DB 7-01F Fire Risers | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 7 | DB 7-01H Distribution Board | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level7 | DB 7-01E Distribution Board | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Dorrit Black Building Level 7 | DB 7-01D Security Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 7 | DB 7-01J Security Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 7 | DB 7-01C Communications Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 7 | DB 7-01G Communications Riser | No | Yes | No | No | No | No | No | No |
| Dorrit Black Building Level 7 | DB 7-13 Switchboard | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 2 | K2 -01A Fire Risers | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 2 | K2 -01C Fire Risers | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 2 | K2 – 03A Distribution Board | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 2 | K2-13A Distribution Board | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 2 | K2-03B Security Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 2 | K2-13B Security Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 2 | K2-03C Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------|--------------------------------|----|-----|----|----|----|----|----|----|
| Kaurna Building Level 2 | K2-13C Communications Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 2 | K2-23 Switch Room | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 3 | K3 -33A Fire Risers | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 3 | K3 -35C Fire Risers | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 3 | K3 – 12A Distribution Board | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 3 | K3-27A Distribution Board | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 3 | K3-12B Security Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 3 | K3-27B Security Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 3 | K3-12C Communications Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 3 | K3-27C Communications Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 4 | K4 -15A Fire Risers | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 4 | K4 -32A Fire Risers | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------|--------------------------------|----|-----|----|----|----|----|----|----|
| Kaurna Building Level 4 | K4 – 14A Distribution Board | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 4 | K4-31A Distribution Board | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 4 | K4-14B Security Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 4 | K4-31B Security Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 4 | K4-14C Communications Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 4 | K4-31C Communications Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 5 | K5 -08A Fire Risers | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 5 | K5 -18A Fire Risers | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 5 | K5 – 09A Distribution Board | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 5 | K5-16A Distribution Board | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 5 | K5-09B Security Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 5 | K5-16B Security Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------|--------------------------------|----|-----|----|----|----|----|----|----|
| Kaurna Building Level 5 | K5-09C Communications Riser | No | Yes | No | No | No | No | No | No |
| Kaurna Building Level 5 | K5-16C Communications Riser | No | Yes | No | No | No | No | No | No |

The University of South Australia Flexible Learning Centre

Confined Space Assessment
19 December 2006

Register of Authorised Access Only

| Flexible Learning Centre University of South Australia | | JUSTIFICATION | | | | | | | |
|---|---|--------------------------------|---------------------------------------|---------------------------------|------------------------------------|--------------------------------|----------------------|--------------------------|-----------------------------|
| Confined Space Audit Date: 19 December 2006 | | AND | | | OR | | | AND | |
| Building and Location | Descriptor | Enclosed or Partially enclosed | Atmospheric Pressure During Occupancy | Not intended as a place of work | Potential atmospheric contaminants | Potential deficiency or excess | May cause engulfment | Restricted entry or exit | Confined space Yes or No |
| Building X Level 1 | FLC1-40 External General AC/Plant Room | No | Yes | No | No | No | No | No | No |
| Building X Level 1 | FLC-18 General AC/Plant Room | No | Yes | No | No | No | No | No | No |
| Building X Level 1 | FLC-18A Electrical Switchboard | No | Yes | No | No | No | No | No | No |
| Building X Level 1 | FLC1-27 MSB/Comms | No | Yes | No | No | No | No | No | No |
| Building X Level 1 | FLC1-48 FHR | No | Yes | No | No | No | No | No | No |
| Building X Level 1 | FLC1-02 PABX Telecommunications | No | Yes | No | No | No | No | No | No |
| Building X Level 1 | FLC1 -03 Lift Motor Room | No | Yes | No | No | No | No | No | No |
| Building X Level 2 | FLC2-26 General AC/Plant Room | No | Yes | No | No | No | No | No | No |
| Building X Level 2 | FLC2-10 MSB/Comms | No | Yes | No | No | No | No | No | No |
| Building X Level 2 | FLC2-52 FHR | No | Yes | No | No | No | No | No | No |

The University of South Australia Whyalla Campus

Confined Space Assessment
17 October 2006

Register of Authorised Access Only

| Whyalla Campus University of South Australia | | JUSTIFICATION | | | | | | | |
|---|---|--------------------------------|---------------------------------------|---------------------------------|------------------------------------|--------------------------------|----------------------|--------------------------|-----------------------------|
| Confined Space Audit Date: 17 October 2006 | | AND | | | OR | | | AND | |
| Building and Location | Descriptor | Enclosed or Partially enclosed | Atmospheric Pressure During Occupancy | Not intended as a place of work | Potential atmospheric contaminants | Potential deficiency or excess | May cause engulfment | Restricted entry or exit | Confined space Yes or No |
| Main Building Level 1 | MB1-09 General A/C Plant Room | No | Yes | No | No | No | No | No | No |
| Main Building Level 1 | MB1- 16B Trap Door Service Tunnel | Yes | Yes | No | No | No | No | No | No |
| Main Building Level 1 | MB1-59 & MB1-60 Ceiling Access Void | No | Yes | No | No | No | No | No | No |
| Main Building Level 1 | Access Door 49 Workshop and store room | No | Yes | No | No | No | No | No | No |
| Main Building Level 1 | Trap Door in MB1- 36 Basement store room | Yes | Yes | No | No | No | No | No | No |
| Main Building Level 1 | MB1-27 Switch Board | No | Yes | No | No | No | No | No | No |
| Main Building Level 1 | MB1-61 Service Duct | No | Yes | No | No | No | No | No | No |
| Main Building Level 1 | MB1-58A Switch Board | No | Yes | No | No | No | No | No | No |
| Main Building Level 2 | MB2-81 General Plant Room | No | Yes | No | No | No | No | No | No |
| Main Building Level 2 | MB2-81A General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|---|--|----|-----|----|-----|----|----|----|----|
| Main Building Level 2 | MB2-66 General A/C Plant Room | No | Yes | No | No | No | No | No | No |
| J Building Level 1 | J1-124 Switch Board Room | No | Yes | No | No | No | No | No | No |
| J Building Level 1 | J1-22A Lift Motor Room | No | Yes | No | No | No | No | No | No |
| J Building Level 1 | Fume Cupboard Microbiology Room | No | Yes | No | No | No | No | No | No |
| J Building Level 1 | J1-110 Plant Room | No | Yes | No | No | No | No | No | No |
| Nurses Training Building Western Side of Access Door | Chemical Neutralising Pit (Ext) Northern Side | No | Yes | No | Yes | No | No | No | No |
| J Building Level 1 | J1-118 General Plant Room 1 | No | Yes | No | No | No | No | No | No |
| J Building Level 1 | J1-106A and J1-106D FHR | No | Yes | No | No | No | No | No | No |
| J Building Level 1 | J1-106C Comms | No | Yes | No | No | No | No | No | No |
| J Building Level 2 | J2-155D FHR | No | Yes | No | No | No | No | No | No |
| J Building Level 2 | J2-155C Comms | No | Yes | No | No | No | No | No | No |
| J Building Level 2 | J2-155A FHR | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|---|----|-----|----|----|----|----|----|----|
| J Building Level 2 | J2-153 FHR | No | Yes | No | No | No | No | No | No |
| Library Building | L1-12 Plant Room Ladder access via Staff Room | No | Yes | No | No | No | No | No | No |
| Library Building | L1-05 SwitchRoom | No | Yes | No | No | No | No | No | No |

The University of South Australia Mawson Lakes

Confined Space Assessment
27 October 2006

Register of Authorised Access Only

| Mawson Lakes Campus University of South Australia | | JUSTIFICATION | | | | | | | |
|--|------------------------------------|---------------------------------------|--|--|---|---------------------------------------|-----------------------------|---------------------------------|-------------------------------------|
| Confined Space Audit Date: 27 October 2006 | | AND | | | OR | | | AND | |
| Building and Location | Descriptor | Enclosed or Partially enclosed | Atmospheric Pressure during occupancy | Not intended as a place of work | Potential atmospheric contaminants | Potential deficiency or excess | May cause engulfment | Restricted entry or exit | Confined space Yes or No |
| Building PH Level 1 | PH1 – 03A Mechanical plant room | No | Yes | No | No | No | No | No | No |
| Building PH Level 1 | PH1 – 09 Switch room | No | Yes | No | No | No | No | No | No |
| Building PH Level 1 | PH1 -11 Mechanical Plant room | No | Yes | No | No | No | No | No | No |
| Building B Level 1 | B1 – 02A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building B Level 1 | B1 – 30A Service Duct | No | Yes | No | No | No | No | No | No |
| Building D Level 1 | D1 -02 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building D Level 1 | D1 – 03 Service Duct | No | Yes | No | No | No | No | No | No |
| Building D Level 1 | D1 – 09 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building D Level 1 | D1 – 18A Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Building D Level 1 | D1 – 20 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building D Level 2 | D2 – 13 Plant Room | No | Yes | No | No | No | No | No | No |
| Building D Level 2 | D2 – 17 Service Duct | No | Yes | No | No | No | No | No | No |
| Building D Level 2 | D2 -21 Plant room | No | Yes | No | No | No | No | No | No |
| Building D Level 2 | D2 -22 Plant room | No | Yes | No | No | No | No | No | No |
| Building D Level 2 | D2 -24 Service Duct | No | Yes | No | No | No | No | No | No |
| Building D Level 2 | D2 – 35 Distribution Board | No | Yes | No | No | No | No | No | No |
| Building D Level 3 | D3 – 05 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building D Level 3 | D3 - 24 Service Duct | No | Yes | No | No | No | No | No | No |
| Building D Level 3 | D3 – 33 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building D Level 3 | D3 - 34 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building J Level 1 | J1 – 07 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-------------------------------------|---------------------------------------|----|-----|----|----|----|----|----|----|
| Building J Level 1 | J1 -07A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building J Level 1 | J1 -09A Plumbing Duct | No | Yes | No | No | No | No | No | No |
| Building J Level 1 | J1 – 17B Switch Room | No | Yes | No | No | No | No | No | No |
| Building J Level 1 | J1 – 17C Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building J Level 2 | J2 – 10 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building J Level 2 | J2 -24B Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building J Level 2 | J2 -28 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building J Level 2 | J2 – 30 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 - 01A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 – 01B Mechanical Services Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 – 01C Fire Services Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------------------|---------------------------------------|----|-----|----|----|----|----|-----|----|
| Garth Boomer Building Level 1 | G1 - 07 Switch Room | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 - 20 General Plant Room | No | Yes | No | No | No | No | Yes | No |
| Garth Boomer Building Level 1 | G1 -21 General Plant Room | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 – 40A Mechanical Services Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 - 40B Electrical Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 - 50 General Plant Room | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 – 42A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 – 46 A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 11 | G1 - 52 General Plant Room | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 1 | G1 - 53 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------------|----------------------------------|----|-----|----|----|----|----|-----|----|
| Garth Boomer Building Level 1 | G1 - 54 General Plant Room | No | Yes | No | No | No | No | Yes | No |
| Garth Boomer Building Level 1 | G1 - 55 General Plant Room | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 2 | G2 - 01A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 2 | G2 - 42A Communications Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 2 | G2 - 01B Communications riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 2 | G2 - 21 General Plant Room | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 2 | G2 - 36 General Plant Room | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 2 | G2 - 42B Electrical Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 2 | G2 - 43A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 3 | G3 - 01A Electrical Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|----------------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Garth Boomer Building Level 3 | G3 – 01B Communications Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 3 | G3 - 21 General Plant Room | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 4 | G4 – 01A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 4 | G4 – 01B Communications Riser | No | Yes | No | No | No | No | No | No |
| Garth Boomer Building Level 4 | G4 - 15 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1 – 20B Hydraulics Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-20C General Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-21 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-24A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-25 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-29B General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|------------------------------------|----|-----|----|----|----|----|----|----|
| Building H Level 1 | H1-30A General Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-32 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-36A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-43 Fire Service Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-43A General Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 1 | H1-44 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2-01A Lift Motor Room | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2-01B General Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2-03B Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2-03C Service Duct | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2-12 Mechanical Services Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2-13 Electrical Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|-------------------------------------|----|-----|----|----|----|----|----|----|
| Building H Level 2 | H2-27 Service Duct | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2-38 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2-40 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 2 | H2-41 General Plant Rooms | No | Yes | No | No | No | No | No | No |
| Building H Level 3 | H3-05A Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 3 | H3-05B Hydraulics Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 3 | H3-16A Mechanical Services Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 3 | H3-17 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 3 | H3-25 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 3 | H3-27 Service Duct | No | Yes | No | No | No | No | No | No |
| Building H Level 3 | H3-28 Data Riser | No | Yes | No | No | No | No | No | No |
| Building H Level 4 | H4-02 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|------------------------------------|----|-----|----|----|----|----|----|----|
| Building H Level 4 | H4-03 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building H Level 4 | H4-04 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building A Level 1 | A1-13 Communications Riser | No | Yes | No | No | No | No | No | No |
| Building A Level 1 | A1-24 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building A Level 1 | A1-25 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building A Level 1 | A1-42 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building A Level 2 | A2-12 Mechanical Services Riser | No | Yes | No | No | No | No | No | No |
| Building A Level 2 | A2-13 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building A Level 2 | A2-28 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building A Level 2 | A2-30 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building A Level 2 | A2-31 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building A Level 2 | A2-32A Mechanical Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|---------------------------------|----|-----|----|----|----|----|----|----|
| Building A Level 3 | A3-01 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building A Level 3 | A3-02 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building A Level 3 | A3-05 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building M Level 1 | M1-06B Service Duct | No | Yes | No | No | No | No | No | No |
| Building M Level 1 | M1-35 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building M Level 2 | M2-02 Hydraulics Riser | No | Yes | No | No | No | No | No | No |
| Building M Level 2 | M2-10 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building M Level 2 | M2-16A Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building M Level 2 | M2-18 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-01A Service Duct | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-02 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-14 Fire Services Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|---------------------------------|----|-----|----|----|----|----|----|----|
| Building R Level 1 | R1-15A Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-16A Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-23 Service Duct | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-24 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-26 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-32B Distribution Board | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-36 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R1-39 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-40A General Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-41E Service Duct | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-41F Service Duct | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-43 Electrical Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|--------------------------------|----|-----|----|----|----|----|----|----|
| Building R Level 1 | R1-49 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-55 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-56 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-57 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-58 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-59 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-60 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-63 Service Riser | No | Yes | No | No | No | No | No | No |
| Building R Level 1 | R1-64 Service Riser | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-01B Service Duct | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-03A Service Duct | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-06 General Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|------------------------------------|----|-----|----|----|----|----|----|----|
| Building R Level 2 | R2-07 Lift Motor Room | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-11A Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-14A Service Duct | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-17A General Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-25 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-27 Communication Riser | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-26 Distribution Board | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-33 Mechanical Services Riser | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-34 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-38A Service Duct | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-38B Switch Room | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-38C Service Duct | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------|-------------------------------------|----|-----|----|----|----|----|----|----|
| Building R Level 2 | R2-46 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building R Level 2 | R2-57 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-21 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-22 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-23 Communication Riser | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-48 Switch Room | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-49 Lift plant | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-51 Switch Room | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-52 Communications Switch Room | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-55 Fire Services Risers | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-56 Service Duct | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-57 Fire Services Risers | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------|--------------------------------|----|-----|----|----|----|----|----|----|
| Building SPRI Level 1 | W1-58 Switch Board | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 1 | W1-59 Fire Service Riser | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 2 | W2-23 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 2 | W2-24 Service Duct | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 2 | W2-25 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 2 | W2-26 Switch Room | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 2 | W2-27 Communications Riser | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 2 | W2-29 Communications Riser | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 2 | W2-30 Fire Services Risers | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 2 | W2-31 Switch Board | No | Yes | No | No | No | No | No | No |
| Building SPRI Level 2 | W2-32 Fire Service Riser | No | Yes | No | No | No | No | No | No |
| Building OC Level 1 | OC1-01A Fire Services Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------|--------------------------------------|----|-----|----|----|----|----|----|----|
| Building OC Level 1 | OC1-01B Mechanical Services Riser | No | Yes | No | No | No | No | No | No |
| Building OC Level 1 | OC1-02 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building OC Level 1 | OC1-02A Service Duct | No | Yes | No | No | No | No | No | No |
| Building OC Level 1 | OC1-37B Service Duct | No | Yes | No | No | No | No | No | No |
| Building OC Level 1 | OC1-38A Fire Service Riser | No | Yes | No | No | No | No | No | No |
| Building N Level 1 | N1-01 Fire Services Risers | No | Yes | No | No | No | No | No | No |
| Building N Level 1 | N1-01A Communications Riser | No | Yes | No | No | No | No | No | No |
| Building N Level 1 | N1-02 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building N Level 1 | N1-12A Duct | No | Yes | No | No | No | No | No | No |
| Building N Level 1 | N1-13A General Plant Room | No | Yes | No | No | No | No | No | No |
| Building N Level 1 | N1-18 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building N Level 2 | N2-06 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|--------------------------------|----|-----|----|----|----|----|----|----|
| Building C Level 1 | C1-02A Fire Service Riser | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1-02B Communication Riser | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1-02C Service Duct | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1-07A Service Duct | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1-09 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1-09B Service Duct | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1-12 Switch room | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1-19 Utility Room | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1-39 Utility Room | No | Yes | No | No | No | No | No | No |
| Building C Level 1 | C1-65A Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building C Level 2 | C2-01A Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building C Level 2 | C2-01B Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|------------------------------------|----|-----|----|----|----|----|----|----|
| Building C Level 2 | C2-01C Fire Hose Reel | No | Yes | No | No | No | No | No | No |
| Building C Level 2 | C2-08 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building C Level 2 | C2-08A Service Riser | No | Yes | No | No | No | No | No | No |
| Building C Level 2 | C2-16A Service Riser | No | Yes | No | No | No | No | No | No |
| Building C Level 3 | C3-01A Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building C Level 3 | C3-01B Communications Riser | No | Yes | No | No | No | No | No | No |
| Building C Level 3 | C3-01C Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building C Level 3 | C3-12 Roof Access | No | Yes | No | No | No | No | No | No |
| Building C Level 3 | C3-14 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building C Level 3 | C3-14A Service Duct | No | Yes | No | No | No | No | No | No |
| Building C Level 3 | C3-27 Roof Access | No | Yes | No | No | No | No | No | No |
| Building C Level 4 | C4-03 Mechanical Services Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|-------------------------------------|----|-----|----|----|----|----|----|----|
| Building C Level 4 | C4-04 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building C Level 4 | C4-05 Lift Motor Room | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-08 Service Duct | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-19B Communications Riser | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-21A Mechanical Services Riser | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-27 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-28 Switch Room | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-29 Transforma | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-30 Switch Room | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-39 Service Duct | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-53A Lift Motor Room | No | Yes | No | No | No | No | No | No |
| Building F Level 1 | F1-65 Distribution Board | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|--------------------------|--|----|-----|----|----|----|----|----|----|
| Building F Level 2 | F2-02 Service Duct | No | Yes | No | No | No | No | No | No |
| Building F Level 2 | F2-15 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building F Level 2 | F2-12 Service Duct | No | Yes | No | No | No | No | No | No |
| Building F Level 2 | F2-47 Service Duct | No | Yes | No | No | No | No | No | No |
| Building F Level 2 | F2-62 Service Duct | No | Yes | No | No | No | No | No | No |
| Building F Level 2 | F2-71 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building F Level 2 | F2-72 Service Duct | No | Yes | No | No | No | No | No | No |
| Building F Level 2 | F2-73 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building F Level 2 | F2-76 Service Duct | No | Yes | No | No | No | No | No | No |
| Mawson Centre Level 1 | MC1 – 17A Mechanical Services Riser | No | Yes | No | No | No | No | No | No |
| Mawson Centre Level 1 | MC1 – 25A General Plant Room | No | Yes | No | No | No | No | No | No |
| Mawson Centre Level 2 | MC2-14 Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------|------------------------------------|----|-----|----|----|----|----|----|----|
| Building GP Level 1 | GP1 - 16 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building GP Level 1 | GP1 – 17 Switch Room | No | Yes | No | No | No | No | No | No |
| Building GP Level 1 | GP1 -17A Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building GP Level 1 | GP1 – 21 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building GP Level 1 | GP1 – 22 Electrical riser | No | Yes | No | No | No | No | No | No |
| Building GP Level 1 | GP1 – 26 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building GP Level 2 | GP 2 – 10 Mechanical plant Room | No | Yes | No | No | No | No | No | No |
| Building GP Level 2 | GP2 – 29C Service Duct | No | Yes | No | No | No | No | No | No |
| Building GP Level 2 | GP2 – 32 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building GP Level 2 | GP2 – 43A Distribution Board | No | Yes | No | No | No | No | No | No |
| Building GP Level 2 | GP2 – 43B Communications Riser | No | Yes | No | No | No | No | No | No |
| Building GP Level 2 | GP2 – 51 Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Building GP Level 2 | GP2 - 55 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building GP Level 2 | GP2 - 56 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building GP Level 2 | GP2 - 57 Communications Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 - 01 Lift Motor Room | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 - 06 Electrical riser | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 - 15B Communications Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 - 16 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P2 - 29C Service Duct | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 - 17 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 - 18 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 - 19 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 - 20 Service Duct | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|----------------------------------|----|-----|----|----|----|----|----|----|
| Building P Level 1 | P1 -21 Service Duct | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 – 21A Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 – 47 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 – 62A Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 1 | P1 – 75 Fire Hose Reel | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 – 02 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 – 24 Hydraulics Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 – 24A Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 – 25 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 - 26 Service Duct | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 – 27 Communications Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 -30 Electrical Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------|-----------------------------------|----|-----|----|----|----|----|----|----|
| Building P Level 2 | P2 – 32 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 – 35 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 – 43B Communications Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 -51A Control Room | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 -52 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building P Level 2 | P2 – 55 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building P Level 3 | P3 - 07 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building K Level 1 | K1 – 10 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building K Level 2 | K2 – 02 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building IW Level 1 | IW1 - 01 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building IW Level 1 | IW – 01A Communications Riser | No | Yes | No | No | No | No | No | No |
| Building IW Level 1 | IW1 - 27 Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|------------------------|-----------------------------------|----|-----|----|----|----|----|----|----|
| Building IW Level 1 | IW1 -01B Fire services Riser | No | Yes | No | No | No | No | No | No |
| Building IW Level 1 | IW1 – 24 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building IW Level 1 | IW1 – 25 Communications Riser | No | Yes | No | No | No | No | No | No |
| Building IW Level 2 | IW2 – 41B Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building IW Level 2 | IW2 – 43 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building IW Level 2 | IW 2 – 47 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building IW Level 2 | IW 2 – 37 Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building IW Level 2 | IW 2 – 52A Fire Services Riser | No | Yes | No | No | No | No | No | No |
| Building Q Level 1 | Q1 - 03 Communications Riser | No | Yes | No | No | No | No | No | No |
| Building Q Level 1 | Q1 – 06 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building Q Level 1 | Q1 – 11 General Plant Room | No | Yes | No | No | No | No | No | No |
| Building Q Level 1 | Q1 – 17 Fire services Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-----------------------|-----------------------------------|----|-----|----|----|----|----|----|----|
| Building Q Level 1 | Q1 - 18 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building Q Level 1 | Q1 - 22 Service Duct | No | Yes | No | No | No | No | No | No |
| Building Q Level 2 | Q2 – 01A Service Duct | No | Yes | No | No | No | No | No | No |
| Building Q Level 2 | Q2 – 07 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building Q Level 2 | Q2 - 23 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1 - 08 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1 - 10 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1 – 11B Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1 – 11D Riser | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1 - 20 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1 - 21 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building E Level 1 | E1 - 22 Communications Riser | No | Yes | No | No | No | No | No | No |

| | | | | | | | | | |
|-------------------------|------------------------------------|----|-----|----|----|----|----|----|----|
| Building E Level 2 | E2 - 04 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building E Level 2 | E2 – 05A Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building E Level 2 | E2 – 19A Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building SCT Level 1 | SCT1 - 14 Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building SCT Level 1 | SCT1 – 38B Electrical Riser | No | Yes | No | No | No | No | No | No |
| Building SCT Level 2 | SCT2 - 27 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |
| Building SCT Level 2 | SCT2 – 48 Mechanical Plant Room | No | Yes | No | No | No | No | No | No |

Magill Campus Action Plan - 28 August 2006

| No: | Location | Descriptor | Recommended Action |
|-----|---------------------------------|---|---|
| 1 | Buildings A, B, C, D,E,F, G & K | Identified Door Access (all keyed) | 1. Signage to be installed indicating "Authorized Personnel Only" |
| 2 | Building D, Level 1 | D1 18, Plant Room | 1. Remove confined space signage from filters |
| 3 | Building G, Level 1 | D12 1-12, Courtyard Hinged Panels AC Plant and Services | 1. Remove confined space signage near hinged panels. |
| 4 | Building G, Level 1 | G1 49 A/C Plant Room | 1. Remove the confine space signage from side of loft floor. 2. Ladder and/or scaffold required to access area |
| 5 | General Site Works | Concrete Slab Control Station Raised Bore Pump Control Station | 1. Remove painted signage of confined space |

City East Campus Action Plan - September 2006

| No: | Location | Descriptor | Recommended Action |
|-----|---|-------------------------------------|--|
| 1 | Buildings Brookman, Centenary, Library, Playford, Bonythan Jubilee & Reid | Identified Door Access (all keyed) | 1. Signage to be installed indicating "Authorized Personnel Only" to all doors |

City West Campus Action Plan - August 2006

| No: | Location | Descriptor | Recommended Action |
|-----|---|---|--|
| 1 | Buildings Yungondi, Way Lee, Sir George Kingston, Rowland Rees, Barbara Hanrahan, Sir Hans Heysen, Elton Mayo Building, Hindley Street Child Care Centre & Catherine Helen Spence | Identified Door Access (all keyed) | 1. Signage to be installed indicating "Authorized Personnel Only" to all doors |
| 2 | Kaurna and Dorrit Black Buildings | All Distribution boards, Data and Communication Risers, General and Airconditioning Plant Rooms | 1. Signage to be installed indicating "Authorized Personnel Only" to all doors |

Flexible Learning Centre Action Plan - 19 December 2006

| No: | Location | Descriptor | Recommended Action |
|-----|--------------------------|---|--|
| 1 | Flexible Learning Centre | All Distribution boards, Data and Communication Risers, General and Airconditioning Plant Rooms | 1. Signage to be installed indicating "Authorized Personnel Only" to all doors |

Whyalla Campus Action Plan – 17 October 2006

| No: | Location | Descriptor | Recommended Action |
|-----|--|-------------------------------------|---|
| 1 | Main, Nurses Training and Library buildings | Identified Door Access (all keyed) | 1. Signage to be installed indicating “Authorized Personnel Only” |
| 2 | All communication, Switchboard and Electrical Risers | Identified Door Access (all keyed) | 1. Signage to be installed indicating “Authorized Personnel Only” |

Mawson Lakes Campus Action Plan – 27 October 2006

| No: | Location | Descriptor | Recommended Action |
|-----|--|-------------------------------------|--|
| 1 | Buildings PH, L, E, D, J, Garth Boomer, H, A, M, R, SPRI, OC, N, Z. C , F, Mawson Centre, GP, P, K, T, IW, Q, E, SCT, Y. | Identified Door Access (all keyed) | 1. Signage to be installed indicating “Authorized Personnel Only” to all doors |